



ELEVATION VIEW (SECTION 4)
N.T.S.

NOTES:

1. FLOATS MUST BE INSTALLED OUT OF THE INFLUENT FLOW TO AVOID TURBULENCE.
2. ELECTRICAL CONDUIT & FITTINGS ACCORDING TO STATE AND LOCAL CODES.
3. PIPING IN WET-WELL AND VALVE PIT IS TO BE CLASS 50 DUCTILE IRON.
4. CONTRACTOR SHALL VERIFY ROOF ACCESS OPENING AND PUMP ANCHOR BOLT DETAILS AND PLACEMENT WITH PUMP MANUFACTURER PRIOR TO CONSTRUCTION.
5. CONTRACTOR SHALL VERIFY VALVE AND DUCTILE IRON PIPE SPOOL DIMENSIONS PRIOR TO CONSTRUCTION.
6. CONTRACTOR SHALL PROVIDE SUBMITTALS FOR DUCTILE IRON PIPE, FITTINGS AND VALVES.
7. ALL BACKFILL AROUND LIFT STATION & VALVE VAULT TO BE COMPACTED TO 95% OF MAX. DENSITY.
8. ALL DIMENSIONS TO BE VERIFIED BY CONTRACTOR BEFORE INSTALLATION.



ENOCH CITY
900 E MIDVALLEY RD
Enoch, UT 84721
Tel. (435) 586-1119

SUBMERSIBLE STORM WATER LIFT STATION

SCALE:
N.T.S.
DATE:
APR. 2024

DETAIL No.:
D11.0A